



EDEN PRAIRIE FIRE DEPARTMENT

Department of Fire Prevention Policy



Prevention and Inspections Valves and Sprinklers

Policy #: 2.2.23

First Issued: April, 2010

Revision: September, 2020

Procedure:

The purpose of this policy is to establish a Standardization of valve arrangements for Automatic Sprinkler Systems reviewed by the City of Eden Prairie department of Fire Prevention.

Valve Arrangements

The following list contains the policies of the City of Eden Prairie Fire Prevention Bureau concerning fire sprinkler systems. The list is not all-inclusive. Unique situations can be reviewed on a case by case basis.

- A) The fire department connection (FDC) shall be provided at a location that is field verified by the AHJ.
- B) A valve is required on each side of the check valve in the riser room, regardless if a PIV is installed.
- C) Water meters for detector checks are not required
- D) Sprinkler systems installed in buildings 3 stories or more in height are required to have shut-off valves/drains, tampers and water-flow devices for each floor including the top floor unless otherwise approved by the City of Eden Prairie Department of Fire Prevention.

Section 3 – Enforcement

- a) Enforcement of the Policy will begin in the plan review stage.
- b) All fire sprinkler design and modification projects are subject to a plan review.
- c) Systems installed after the installment of the policy, and are found delinquent may be subject to remediation. Including, but not limited to; removal and reinstallation.

Section 4 – Appeals

- a) Appeals or request to amend this Statement of Policy should be made directly to the Fire Prevention Bureau. At any time, a Fire Code Official, as appointed by the Fire Chief, holds the right to amend or approve variances to this policy.
- b) The Fire Prevention Bureau can be contacted by calling 952-949-8556 or via email at firecode@edenprairie.org.